



**TRANSPORTATION &
CIVIC WORKS DEPARTMENT**

Water Analysis Test Results for Millennium Ponds August 12, 2019

The City of Castlegar has completed a water analysis of all 3 ponds and the following are the results:

POND #1 RESULTS	POND #2 RESULTS	POND #3 RESULTS
1 CFU/100mL	2 CFU/100mL	3 CFU/100mL

*Results under 400 CFU/100ML are considered an allowable limit as per Interior Health.